



## OUTDOOR INSTALLATION

Note: 6" of clearance on the back side, and 12" of clearance on the control valve side from device center-point is required.

If installed outdoors, freeze protection must be provided for device and exposed piping.

Any exemptions must be approved by the Public Works Director or his/her designee.



City of Red Oak  
Public Works  
Department

½" - 2" Spill Resistant Vacuum Breaker and Pressure  
Vacuum Breaker Backflow Prevention Assembly  
Installation

Public Works Department  
411 W Red Oak Road  
Building D  
972-576-3414